



HEBEL CORRIDOR WALL
BATHROOM POD ONE SIDE

Hebel1176




VERTICAL CROSS SECTION DETAIL A-A



DETAIL PLAN VIEW

PLAN VIEW




PERSPECTIVE VIEW

CORRIDOR WALL						
CODE	APPLICATION	WALL WIDTH	WALL HEIGHT	FRL ^(a)	R _w ^(b)	SYSTEM COMPONENT VARIATIONS
						LINING A MIN. GAP INSULATION ^(c) LINING B
Hebel1176	CORRIDOR TO BATHROOM POD	168mm	UP TO 3.3m HIGH	-/90/90 FOR WALL HEIGHTS UP TO 3.3m	≥50	13mm GYPROCK CD 10mm 75mm BRADFORD ACOUSTIGARD 11 6mm FIBRE CEMENT


- (A) FRL VALUES SHOULD BE READ IN CONJUNCTION WITH CSIRO FIRE OPINION FCO FCO-3036. FOR WALLS > 3.3m AND ≤ 4.65m, HEBEL POWERPANEL CAGED TONGUE & GROOVE WILL ACHIEVE A FRL OF -/120/120.
- (B) ACOUSTIC VALUES SHOULD BE READ IN CONJUNCTION WITH ACOUSTIC LOGIC ASSESSMENT REPORT 20151586.3/0707AR/5/GW.
- (C) WHERE BATHROOM PODS ARE INSTALLED ALONG SIDE A FACADE WALL AND ONE POD WALL FORMS PART OF THE FACADE WALL CONSTRUCTION, THE INSULATION USED IN THIS WALL MUST BE DEEMED NON-COMBUSTIBLE.

GENERAL NOTES:

1. INSULATION & PLASTERBOARD ARE REQUIRED AROUND BATHROOM POD PERIMETER TO CONCRETE SOFFIT.
2. FOR MORE CONSTRUCTION AND PRODUCT INFORMATION REFER TO HEBEL DESIGN AND INSTALLATION GUIDE FOR HIGH RISE APARTMENTS, HOTELS, STUDENT ACCOMMODATION - CORRIDOR, INTERTENANCY, SHAFT & SERVICE WALLS (HELT117).



CSR BUILDING PRODUCTS LTD
HEBEL ROAD, TULLAH & 90 BELMONT RD, NORTH RYDE NSW 2113
A.B.N. 55 008 631 356 Ph: 1300 369 448
www.hebelaustralia.com.au



The better way to build
CSR Building Products is Limited
A.B.N. 55 008 631 356

SYSTEM CODE	TITLE
Hebel1176	HEBEL CORRIDOR WALLS WITH BATHROOM POD
DESIGN GUIDE REFERENCE	SCALE
---	1:5 @ A3
SHEET NO.	SHEET SIZE
1 of 1	A3
CHECK	DRAWN
SD	ET
REVISION	DATE
E	15.04.20