



# HEBEL INTERTENANCY WALL BATHROOM POD EACH SIDE

Hebel1178




VERTICAL CROSS SECTION DETAIL A-A



DETAIL PLAN VIEW

## PLAN VIEW



## PERSPECTIVE VIEW

NTS

CODE	APPLICATION	WALL WIDTH	WALL HEIGHT	FRL (a)	R <sub>+</sub> +C <sub>+</sub> (b)	SYSTEM COMPONENT VARIATIONS	
						LININGS	INSULATION (c)
Hebel1178	BATHROOM POD TO BATHROOM POD	235mm	UP TO 3.3m HIGH	-/90/90 FOR WALL HEIGHTS UP TO 3.3m	≥50	6mm FIBRE CEMENT	75mm BRADFORD ACOUSTIGARD 11

- (A) FRL VALUES SHOULD BE READ IN CONJUNCTION WITH CSIRO FIRE OPINION FCO FCO-3036. FOR WALLS > 3.3m AND ≤ 4.65m, HEBEL POWERPANEL CAGED TONGUE & GROOVE WILL ACHIEVE A FRL OF -/120/120.  
 (B) ACOUSTIC VALUES SHOULD BE READ IN CONJUNCTION WITH ACOUSTIC LOGIC ASSESSMENT REPORT 2015/1586.3/0707/AR5/GW.  
 (C) WHERE BATHROOM PODS ARE INSTALLED ALONG SIDE A FACADE WALL AND ONE POD WALL FORMS PART OF THE FACADE WALL CONSTRUCTION, THE INSULATION USED IN THIS WALL MUST BE DEEMED NON-COMBUSTIBLE.

### GENERAL NOTES:

- INSULATION & PLASTERBOARD ARE REQUIRED AROUND BATHROOM POD PERIMETER TO CONCRETE SOFFIT.
- FOR MORE CONSTRUCTION AND PRODUCT INFORMATION REFER TO HEBEL DESIGN AND INSTALLATION GUIDE FOR HIGH RISE APARTMENTS, HOTELS, STUDENT ACCOMMODATION - CORRIDOR, INTERTENANCY, SHAFT & SERVICE WALLS (HELT117).



CSR BUILDING PRODUCTS LTD  
 HEBEL BUILDING SYSTEMS  
 LOCKED BAG 1346 NORTHRYDE NSW 1570  
 A.B.N. 55 008 631 356 Ph: 1300 969 448  
 www.hebelintertenancy.com.au



1178 Intertenancy Wall  
 Phone: 02 48633300  
 Fax: 02 48633300

SYSTEM CODE	TITLE	SCALE	SHEET SIZE	DRAWN	DATE
Hebel1178	HEBEL INTERTENANCY WALLS WITH BATHROOM POD	1:5 @ A3	A3	ET	15.04.20
DESIGN CODE REFERENCE		SHEET NO.	1 of 1	CHECK	REVISION
---				SD	E